Certificate of Compliance

You have been awarded:

Intertek WH US Mark for Category D - Door/frame Assemblies

Standards: UL 10(c) (2016), NFPA 252 (2017)

Certificate number: WHI17–18405332

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: Abanos Furniture & Decoration Industry LLC
P.O. Box 114480
Dubai Investment Park 1
Dubai
United Arab Emirates

Product: Abanos - UL 10c - 60 minutes - Single Leaf Doorset
Spec ID: 41922
Fire Rating: 60 Min Positive Pressure
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: July 11, 2017
Date of expiry: December 31, 2026
Issue status: 10

Authorized By: _____
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Product Covered

Latched single acting single leaf doorset with vision panel

Product Description

Latched single acting single leaf wooden doorset with vision panel.

Maximum dimensions:
Door Frame - 1276 x 2464 x 200mm (w x h x jamb depth)
Door Leaf - 1216 x 2432 x 54mm (w x h x door thickness)
Vision panel glass - 250 x 950 x 5mm (w x h x thickness)

Limitations:

Minimum Latch throw: 19mm (3/4 inch)

Double leaf door not allowed

Ratings

The latched single acting single leaf wooden doorset qualifies for 60 minute fire rating according to the following standards:

UL 10C (2016)
NFPA 252 (2017)