Certificate of Compliance

You have been awarded:

WH Service Mark 2014 for Category D - Door/frame Assemblies

Standards: BS 476 Part 22 (1987), EN 1634-1:2014+A1(2018)

Certificate number: WHI23–18405334

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Organization: Abanos Furniture & Decoration Industry LLC
P.O. Box 114480
Dubai Investment Park 1
Dubai
United Arab Emirates

Product: Abanos - Desert Board - Palm Strand Board Fire Door And Frame Assembly - 90-Minute - EN 1634-1/ BS 476 Part 22.
Spec ID: 74417
Fire Rating: 90 Minute Fire Rated
Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.
Initial registration: September 7, 2023
Date of expiry: December 31, 2026
Issue status: 4

Authorized By:
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-439-5667 Fax: 847-439-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

LISTING INFORMATION

Product Covered
Abanos - Desert Board - Palm Strand Board Fire Door And Frame Assembly - 90-Minute - EN 1634-1/ BS 476 Part 22.

Product Description
Abanos - Desert Board - Palm Strand Board Fire Door Core.

Door Frame - Palm Strand Board, minimum density - 800 kg/m^3 64mm wide x 150mm depth, stop height - 18mm.

Door leaf is bonded with three layers of 21.8mm thick palm strand board core, minimum density - 800 kg/m^3, Overall leaf thickness: 64mm.

Tested Sizes:
Door frame - 1094 x 2452 x 150mm (w x h x jamb depth)
Door leaf - 1000 x 2400 x 64mm (w x h x thickness)

Limitations:
Minimum latch throw: 12mm
Supporting construction - Masonry wall assemblies.

FIRE RATINGS
The product noted above has been evaluated according to the requirements of the standards EN 1634-1:2014+A1:2018 and BS 476 Part 22 and has qualified for the following fire ratings:

Criterion	Rating
Integrity	90 Minutes
Insulation (I_2)	90 Minutes