

# INTERTEK DIRECTORY OF BUILDING PRODUCTS

## Al Talah - 44mm thick Palm Strand Board Fire Door Core - 30-Minute - UL 10C/UL 10B/ NFPA 252

Company: Al Talah Board Manufacturing Company Ltd

**Product Covered**

Al Talah – 44mm thick Palm Strand Board Fire Door Core - 30-Minute – UL 10C/UL 10B/ NFPA 252

**Product Description**

Door leaf core is constructed using either a single 44mm thick Palm Strand Board core (density - 650 kg/m<sup>3</sup>) or two 21.8mm thick Palm Strand Board core (density – 880 kg/m<sup>3</sup> ) bonded together; Overall leaf thickness: 44mm

Tested Door Size: 1000 x 2442 x 44mm (w x h x thickness)

**FIRE RATINGS**

The product noted above has been evaluated according to the requirements of the standard UL 10C and has qualified for up to **30 minutes (½ hour)** positive pressure fire rating.

Also meets the requirements of UL 10B (Negative Pressure Fire Rating) and NFPA 252 (Positive Pressure Fire Rating).

[LISTING REPORT](#)   [CERTIFICATE OF COMPLIANCE](#)   [RETURN TO SEARCH](#)

### ATTRIBUTES

Certificate Date of Expiry	December 31, 2025
Certificate Date of Initial Registration	September 18, 2024
Certificate Number	WHI24-39132913
Criteria	UL 10(c) (2016)
Criteria	UL 10(b) (2008) (R2020)
Criteria	NFPA 252 (2022)
CSI Code	08 10 00 Doors and Frames
Fire Resistance	30 Minute Fire Rated
Listing Section	FIRE DOOR COMPONENTS
Spec ID	79925

## DESIGN DOCUMENTS

*No Results*

## PUBLIC DOCUMENTS

*No Results*



Intertek [Warnock Hersey Mark](#)



Intertek [ETL Listed Mark](#)



© Intertek Group plc

All other product or service names are the property of their respective owners.

[Disclaimer](#)

[Terms](#)

[Privacy](#)

[Cookies](#)

[Client Portals](#)

**TOTAL QUALITY.**